

Maxxam Job Number: B5B3143
 Report Date: 2016/01/12

McElhanney Consulting Services Ltd.
 Client Project #: VILLAGE OF TAHSIS

RESULTS OF CHEMICAL ANALYSES OF WATER

Maxxam ID		NW7830	
Sampling Date		2015/12/22 09:30	
COC Number		08411437	
	UNITS	COMMUNITY WELL#1	RDL
Parameter			
Subcontract Parameter	N/A	ATTACHED	N/A
ANIONS			
Nitrite (N)	mg/L	<0.0050	0.0050
Calculated Parameters			
Nitrate (N)	mg/L	0.072	0.020
Misc. Inorganics			
Total Organic Carbon (C)	mg/L	<0.50	0.50
Anions			
Dissolved Sulphate (SO4)	mg/L	3.77	0.50
Dissolved Chloride (Cl)	mg/L	1.3	0.50
MISCELLANEOUS			
Tannins and Lignins	mg/L	<0.10	0.10
Nutrients			
Nitrate plus Nitrite (N)	mg/L	0.072	0.020
Misc. Organics			
Phenols	mg/L	<0.0010	0.0010
Physical Properties			
Conductivity	uS/cm	116	1.0
pH	pH	8.07	N/A
Physical Properties			
Total Dissolved Solids	mg/L	50	10

RDL = Reportable Detection Limit

N/A = Not Applicable

Results relate only to the items tested.